

Stack Height Calculation

Flue Gases

Flow		150,850 Nm ³ /h	
Temperature	T _d	134 °C	
Moisture	% v/v	16.4%	
Oxygen	% v/v dry	4.9%	
Reference Flow	Dry, 11% O ₂	135,234 Nm ³ /h	
	V	224,894 Actual m ³ /h	62.470 m ³ /s
Heat release	Q	6.563 MW	
Exit Velocity	Required	20.0 m/s	
Stack Diameter	Required Max	1.994 m	
	Actual	1.950 m	
Exit Velocity	Actual	20.9 m/s	

$$Q = \frac{V \left(1 - \frac{283}{T_d}\right)}{2.9} \text{ (MW)}$$

Pollution Index Calculation

Pollutant	Emission Concentration	Discharge Rate	Guideline Concentration	Background Concentration	Pollution Index
	At Reference Conditions mg/m ³	D g/s	G _d mg/m ³	B _c mg/m ³	P _i m ³ /s
HCl	30	1.127	0.800	0.003	1,415
SO ₂	100	3.757	0.266	0.015	14,942
Total Acid gases					16,357
CO	375	14.087	10	0.548	1,490
Particulate	30	1.127	0.050	0.043	165,728
NO ₂	300	11.270	0.200	0.049	74,435
				Pollution Index P_i	165,728

$$P_i = \frac{D}{(G_d - B_c)} \times 1000$$

G_d values are taken from National Air Quality Strategy for short term quality standards. See reference Library>ADMS section> AQSO or from D1 where no EQS exists

P_i for calculation purposes is maximum value in table above

Buoyancy Calculation

	a	-1.4401
	b	0.5283
Uncorrected Stack Height	U _b	20.76
Minimum	U _b min	3.06 <U _b

Q>1MW

$$a = -0.84 - 0.1 \exp(Q^{0.31})$$

$$b = 0.46 + 0.011 \exp(Q^{0.31})$$

$$U_b = 10^a \times P_i^b$$

Q<1MW

$$a = -1.11 - 0.19 \times \log Q$$

$$b = 0.49 + 0.005 \times \log Q$$

$$U_b \text{ min} = 1.7 + 0.25 \times Q^{0.9}$$

Momentum Calculation

Velocity	w	20.9 m/s
Stack Diameter	d	1.95 m
Momentum	M	909
	x	-1.046
	y	4.054
	z	-13.403
	Log(U _m)	1.739
	U _m	54.86
	U _m min	7.25 <U _m

$$M = \frac{283}{T_d} \times V \times w$$

$$\log_{10} U_m = x + \sqrt{y \log_{10} P_i + z}$$

$$x = -3.7 + (\log_{10} M)^{0.9}$$

$$U_m \text{ min} = 0.82 \times M^{0.32}$$

$$y = 5.9 - 0.624 \log_{10} M$$

$$z = 4.24 - 9.7 \log_{10} M + 1.47 (\log_{10} M)^2 - 0.07 (\log_{10} M)^3$$

Buildings

Affected radius	5U _m	274.3 m	
Uncorrected height	U	20.76 U _b	(lesser of U _m and U _b)
	A	2.64 U _m /U _b	

$$C = H + 0.6 \left\{ U + (25H - U) \left(1 - A^{-U/H} \right) \right\}$$

Buildings and Structures within 5U_m

	Straw Barn 1	Straw Barn 2	Wood Storage	Turbine Hall	Boiler House
Distance from stack	78.50	21.00	77.50	40.70	17.80
Height	18.00	18.00	14.10	12.00	32.00
Width (perpendicular to line of stack)	73.79	73.79	14.74	43.24	33.24
K (lesser of H or B)	18.00	18.00	14.10	12.00	32.00
T = (H+1.5K)	45.00	45.00	35.25	30.00	80.00
Number of Buildings	Do not Ignore 5	Do not Ignore 5	Do not Ignore 5	Do not Ignore 5	Do not Ignore 5

Height	H _m	32.00
	T _m	80.00 H+1.5K
	C	61.1
	C*	61.1
Multiple Buildings?	YES	Use C*
Is U>2.5H?	NO	Use C*
Is U>T with multiple buildings?	NO	Use C*
	C	61.1

$$C^* = H_m + \left(1 - \frac{H_m}{T_m} \right) \times \left[U + (T_m - U) \times \left(1 - A^{-U/H_m} \right) \right]$$

CORRECTED STACK HEIGHT = 62 m
Rounded up to nearest metre